

换气次数大于2次/h的面积比		
换气次数大于2次/h的面积	3942.43	m²
总面积	4485.16	m²
面积比例R _R	87.90	%

分类	体积 (m³)	面积 (m²)	换气次数 (次/h)
○建筑			
└○第1层			
└○1001[房间]	2913.27	647.39	14.46
└○1002[房间]	324	72	5.64
└○1003[房间]	162	36	0
└○1004[房间]	162	36	0
└○1005[房间]	162	36	17.57
└○1006[房间]	162	36	15.86
└○1007[房间]	162	36	0
└○1008[房间]	81	18	0
└○1009[房间]	81	18	0
└○1010[房间]	68.65	15.26	20.02
└○1011[房间]	67.8	15.07	18.91
└○1012[房间]	25.55	5.68	0
└1013[房间]	16.76	3.72	0
└1014[房间]	16.76	3.72	0
└○第2层			
└○2001[房间]	324	72	1.4
└○2002[房间]	324	72	7.93
└○2003[房间]	162	36	7.13
└○2004[房间]	162	36	9.51
└○2005[房间]	91.38	20.31	13.45
└○2006[房间]	86.28	19.17	25.08
└○2007[房间]	78.06	17.35	14.42
└○2008[房间]	71.82	15.96	16.57
└2009[房间]	16.76	3.72	0
└2010[房间]	16.76	3.72	0
└○2011[房间]	2471.63	549.25	4.1
└○2012[房间]	410.51	91.22	0
└○2013[房间]	81	18	15.17
└○第3层			
└○3001[房间]	1859.46	413.21	5.95
└○3002[房间]	486	108	11.07
└○3003[房间]	486	108	19.39
└○3004[房间]	324	72	17.74
└○3005[房间]	162	36	10.11
└○3006[房间]	162	36	12.82
└○3007[房间]	91.38	20.31	0
└○3008[房间]	86.28	19.17	19.58
└○3009[房间]	78.06	17.35	8.92
└○3010[房间]	71.82	15.96	10.1
└3011[房间]	16.76	3.72	0
└3012[房间]	16.76	3.72	0
└○第4层			
└○4001[房间]	1957.69	435.04	4.52
└○4002[房间]	486	108	9.64
└○4003[房间]	324	72	23.17
└○4004[房间]	269.74	59.94	0
└○4005[房间]	162	36	16.46
└○4006[房间]	162	36	20.51
└○4007[房间]	162	36	19.13
└○4008[房间]	91.38	20.31	0
└○4009[房间]	86.28	19.17	22.28
└○4010[房间]	78.06	17.35	13.48
└○4011[房间]	71.82	15.96	15.41
└4012[房间]	16.76	3.72	0
└4013[房间]	16.76	3.72	0
└○第5层			
└○5001[房间]	1939.39	430.97	5.83
└○5002[房间]	486	108	12.66
└○5003[房间]	324	72	0
└○5004[房间]	324	72	15.89
└○5005[房间]	162	36	32.25
└○5006[房间]	162	36	4.77
└○5007[房间]	91.38	20.31	0
└○5008[房间]	86.28	19.17	15.3
└○5009[房间]	78.06	17.35	7.43
└○5010[房间]	71.82	15.96	11.44
└5011[房间]	16.76	3.72	0
└5012[房间]	15.58	3.46	0
└第6层			