

中康嘉苑 热负荷计算书_详尽表

楼号	楼层	户型	房间	负河源			传热系数	温差修正系数	耗热量修正			修正后热负荷	冷风渗透耗热量	外门冷风侵入耗热量	总热负荷	
				名称	面积计算				朝向	风力	间歇附加					
					K	α	Xch	Xf				Xjan	Q1	Q2	Q3	Q1+Q2+Q3
D西户			1001[厨房]	西外墙	1.5	3.2	4.7	0.44	1.00	-0.05	0.00	0.00	55.9			55.9
				北外墙	4.1	3.2	12.915-3.7	0.44	1.00	0.10	0.00	0.00	125.6			125.6
				北外窗_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	28.0		244.2
				东内墙	2.3	3.2	7.2	1.45	0.70	0.00	0.00		197.7			197.7
			房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0			595.3	28.0	0.0	623.3
			1002[卫]	北外墙	1.8	3.2	5.670-1.3	0.44	1.00	0.10	0.00	0.00	72.0			72.0
				北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	90.6	24.1		114.7
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			162.6	24.1	0.0	186.7
			1003[卧室]	北外墙	3.3	3.2	10.395-2.9	0.44	1.00	0.10	0.00	0.00	123.2			123.2
				北外窗_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	0.00	203.9	31.6		235.5
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			327.2	31.6	0.0	358.7
			1004[卫]	西外墙	3.6	3.2	11.3	0.44	1.00	-0.05	0.00	0.00	169.0			169.1
				北外墙	1.8	3.2	5.670-1.3	0.44	1.00	0.10	0.00	0.00	75.3			75.3
				北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	24.1		118.8
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			339.1	24.1	0.0	363.1
			1005[主卧室]	西外墙	6.8	3.2	21.3	0.44	1.00	-0.05	0.00	0.00	317.0			317.0
				南外墙	3.9	3.2	12.285-4.6	0.44	1.00	-0.20	0.00	0.00	97.9			97.9
				矩形凸窗_嵌									484.7			484.7
				东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	23.4		96.8
				西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	24.8		98.2
				南外窗_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	35.6		285.1
				顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
				底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
				东外墙	0.8	3.2	2.5	0.44	0.70	-0.05	0.00	0.00	26.3			26.3
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			925.8	0.0	0.0	925.8
				南外墙	0.7	3.2	2.2	0.44	1.00	-0.20	0.00	0.00	26.3			26.3
				南外墙	6.4	3.2	20.160-13.8	0.44	0.70	-0.20	0.00	0.00	53.5			53.5

7号 楼1 层			1006[客餐 厅]	南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	55.8	0.0	582.5
				东内墙	4.8	3.2	15.120-2.8	1.45	0.70	0.00	0.00		425.0			425.0
				东内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1162.4	55.8	0.0	1218.2
			1007[卧室]	南外墙	3.4	3.2	10.553-4.0	0.44	1.00	-0.20	0.00	0.00	83.2			83.2
				矩形凸窗_嵌									450.9			450.9
				东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	23.4		96.8
				西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	24.8		98.2
				南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	33.5		251.8
				顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
				底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
				北内墙	3.4	3.2	10.6	1.45	0.70	0.00	0.00		362.9			362.9
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			897	0.0	0.0	897.0
			户型小计										4409.3	163.6	0.0	4572.9
			1008[厨房]	东外墙	1.5	3.2	4.7	0.44	1.00	-0.05	0.00	0.00	55.9			55.9
				北外墙	4.1	3.2	12.915-3.7	0.44	1.00	0.10	0.00	0.00	125.6			125.6
				北外窗_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	28.0		244.2
				西内墙	2.3	3.2	7.2	1.45	0.70	0.00	0.00		197.7			197.7
			房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0			595.3	28.0	0.0	623.3
			1009[卫]	北外墙	1.8	3.2	5.670-1.3	0.44	1.00	0.10	0.00	0.00	72.0			72.0
				北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	90.6	24.1		114.7
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			162.6	24.1	0.0	186.7
			1010[卧室]	北外墙	3.3	3.2	10.395-2.9	0.44	1.00	0.10	0.00	0.00	123.2			123.2
				北外窗_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	0.00	203.9	31.6		235.5
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			327.2	31.6	0.0	358.7
			1011[卫]	东外墙	3.6	3.2	11.3	0.44	1.00	-0.05	0.00	0.00	169.0			169.1
				北外墙	1.8	3.2	5.670-1.3	0.44	1.00	0.10	0.00	0.00	75.3			75.3
				北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	24.1		118.8
			房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			339.1	24.1	0.0	363.1
				南外墙	3.9	3.2	12.285-4.6	0.44	1.00	-0.20	0.00	0.00	97.9			97.9
				矩形凸窗_嵌									484.7			484.7
				东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	23.4		96.8
				西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	24.8		98.2

D东户	1012[主卧室]	南外窗_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	35.6		285.1
		顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
		底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
		东外墙	6.8	3.2	21.3	0.44	1.00	-0.05	0.00	0.00	317.0			317.0
		西外墙	0.8	3.2	2.5	0.44	0.70	-0.05	0.00	0.00	26.3			26.3
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			925.8	0.0	0.0	925.8
	1013[客餐厅]	南外墙	0.7	3.2	2.2	0.44	1.00	-0.20	0.00	0.00	27.9			27.9
		南外墙	6.4	3.2	20.160-13.8	0.44	0.70	-0.20	0.00	0.00	56.9			56.9
		南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	58.8	0.0	585.4
		西内墙	4.8	3.2	15.120-2.8	1.45	0.70	0.00	0.00		425.0			425.0
		西内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1167.4	58.8	0.0	1226.1
	1014[卧室]	南外墙	3.4	3.2	10.553-4.0	0.44	1.00	-0.20	0.00	0.00	83.2			83.2
		矩形凸窗_嵌									450.9			450.9
		东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	23.4		96.8
		西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	24.8		98.2
		南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	33.5		251.8
		顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
		底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
		北内墙	3.4	3.2	10.6	1.45	0.70	0.00	0.00		362.9			362.9
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			897	0.0	0.0	897.0
	户型小计										4414.3	166.5	0.0	4580.9
	楼层小计										8823.7	330.1	0.0	9153.8
		2001[厨房]	西外墙	1.5	3.1	4.7	0.44	1.00	-0.05	0.00	55.0			55.0
			北外墙	4.1	3.1	12.710-3.7	0.44	1.00	0.10	0.00	122.8			122.8
			北外窗_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	216.1	21.2		237.4
			东外墙	2.3	3.1	7.1	0.44	1.00	-0.05	0.00	84.3			84.3
		房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0		478.3	21.2	0.0	499.5
		2002[卫]	北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	70.5			70.5
			北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	90.6	18.2		108.9
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0		161.1	18.2	0.0	179.4
		2003[卧室]	北外墙	3.3	3.1	10.230-2.9	0.44	1.00	0.10	0.00	120.5			120.5
			北外窗_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	203.9	23.9		227.9

7号 楼	D西户	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			324.5	23.9	0.0	348.4
		2004[卫]	西外墙	3.6	3.1	11.2	0.44	1.00	-0.05	0.00	0.00	166.4			166.4
			北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	73.7			73.7
			北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	18.2		113.0
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			334.8	18.2	0.0	353.1
		2005[主卧室]	西外墙	6.8	3.1	20.9	0.44	1.00	-0.05	0.00	0.00	311.9			311.9
			南外墙	3.9	3.1	12.090-4.6	0.44	1.00	-0.20	0.00	0.00	95.4			95.4
			矩形凸窗_嵌									457.6			457.6
			东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	15.4		88.8
			西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	17.9		91.3
			南外窗_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	23.4		272.9
			顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
			底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
			东外墙	0.8	3.1	2.5	0.44	0.70	-0.05	0.00	0.00	25.9			25.9
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			890.9	0.0	0.0	890.9
		2006[客餐厅]	南外墙	0.7	3.1	2.2	0.44	1.00	-0.20	0.00	0.00	25.9			25.9
			南外墙	6.4	3.1	19.840-13.8	0.44	0.70	-0.20	0.00	0.00	50.8			50.8
			南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	35.6	0.0	562.3
			东内墙	3.7	3.1	11.470-2.8	1.45	0.70	0.00	0.00		299.5			299.5
			东内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
			东外墙	1.1	3.1	3.410-2.0	0.44	1.00	-0.05	0.00	0.00	20.0			20.0
			东外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	19.1	0.0	147.8
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1182.5	54.7	0.0	1237.2
		2007[卧室]	南外墙	3.4	3.1	10.385-4.0	0.44	1.00	-0.20	0.00	0.00	81.0			81.0
			矩形凸窗_嵌									424.5			424.5
			东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	15.4		88.8
			西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	17.9		91.3
			南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	22.1		240.4
			顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
			底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
			北内墙	3.4	3.1	10.4	1.45	0.70	0.00	0.00		357.1			357.1
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			862.7	0.0	0.0	862.7
		户型小计										4234.8	136.3	0.0	4371.1

安全层	D东户	2008[厨房]	东外墙	1.5	3.1	4.7	0.44	1.00	-0.05	0.00	0.00	55.0			55.0
			北外墙	4.1	3.1	12.710-3.7	0.44	1.00	0.10	0.00	0.00	122.8			122.8
			北外墙_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	21.2		237.4
			西外墙	2.3	3.1	7.1	0.44	1.00	-0.05	0.00	0.00	84.3			84.3
房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0			478.3	21.2	0.0	499.5		
2009[卫]		北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	70.5			70.5	
		北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	90.6	18.2		108.9	
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			161.1	18.2	0.0	179.4		
2010[卧室]		北外墙	3.3	3.1	10.230-2.9	0.44	1.00	0.10	0.00	0.00	120.5			120.5	
		北外墙_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	0.00	203.9	23.9		227.9	
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			324.5	23.9	0.0	348.4		
2011[卫]		东外墙	3.6	3.1	11.2	0.44	1.00	-0.05	0.00	0.00	166.4			166.4	
		北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	73.7			73.7	
		北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	18.2		113.0	
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			334.8	18.2	0.0	353.1		
2012[主卧室]		南外墙	3.9	3.1	12.090-4.6	0.44	1.00	-0.20	0.00	0.00	95.4			95.4	
		矩形凸窗_嵌									457.6			457.6	
		东外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	15.4		88.8	
		西外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	17.9		91.3	
		南外墙_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	23.4		272.9	
		顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4	
		底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4	
		东外墙	6.8	3.1	20.9	0.44	1.00	-0.05	0.00	0.00	311.9			311.9	
		西外墙	0.8	3.1	2.5	0.44	0.70	-0.05	0.00	0.00	25.9			25.9	
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			890.9	0.0	0.0	890.9		
2013[客餐厅]		南外墙	0.7	3.1	2.2	0.44	1.00	-0.20	0.00	0.00	27.5			27.5	
		南外墙	6.4	3.1	19.840-13.8	0.44	0.70	-0.20	0.00	0.00	54.0			54.0	
		南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	37.5	0.0	564.1	
		西内墙	3.7	3.1	11.470-2.8	1.45	0.70	0.00	0.00		299.5			299.5	
		西内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9	
		西外墙	1.1	3.1	3.410-2.0	0.44	1.00	-0.05	0.00	0.00	21.0			21.0	
		西外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	22.5	0.0	151.3	
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1188.4	60.0	0.0	1248.4		

D西户	2014[卧室]	南外墙	3.4	3.1	10.385-4.0	0.44	1.00	-0.20	0.00	0.00	81.0		81.0
		矩形凸窗_嵌									424.5		424.5
		东外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	15.4	88.8
		西外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	17.9	91.3
		南外墙_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	22.1	240.4
		顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1		2.1
		底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1		2.1
		北内墙	3.4	3.1	10.4	1.45	0.70	0.00	0.00		357.1		357.1
		房间小计	室内温度℃	18	室外温度℃	-6.2	房高修正	0			862.7	0.0	862.7
		户型小计									4240.6	141.6	4382.3
	楼层小计										8475.4	278.0	8753.3
	3001[厨房]	西外墙	1.5	3.1	4.7	0.44	1.00	-0.05	0.00	0.00	55.0		55.0
		北外墙	4.1	3.1	12.710-3.7	0.44	1.00	0.10	0.00	0.00	122.8		122.8
		北外墙_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	12.3	228.4
		东外墙	2.3	3.1	7.1	0.44	1.00	-0.05	0.00	0.00	84.3		84.3
		房间小计	室内温度℃	13	室外温度℃	-6.2	房高修正	0			478.3	12.3	490.5
		3002[卫]	北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	70.5		70.5
			北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	90.6	10.5	101.2
		房间小计	室内温度℃	18	室外温度℃	-6.2	房高修正	0			161.1	10.5	171.7
		3003[卧室]	北外墙	3.3	3.1	10.230-2.9	0.44	1.00	0.10	0.00	120.5		120.5
			北外墙_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	203.9	13.8	217.8
		房间小计	室内温度℃	18	室外温度℃	-6.2	房高修正	0			324.5	13.8	338.3
		3004[卫]	西外墙	3.6	3.1	11.2	0.44	1.00	-0.05	0.00	166.4		166.4
			北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	73.7		73.7
			北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	94.8	10.5	105.3
		房间小计	室内温度℃	18	室外温度℃	-6.2	房高修正	0			334.8	10.5	345.4
		3005[主卧室]	西外墙	6.8	3.1	20.9	0.44	1.00	-0.05	0.00	311.9		311.9
			南外墙	3.9	3.1	12.090-4.6	0.44	1.00	-0.20	0.00	95.4		95.4
			矩形凸窗_嵌								418.4		418.4
			东外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	73.4	3.5	76.9
			西外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	73.4	8.5	81.9
			南外墙_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	249.5	5.4	254.9
			顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00	2.4		2.4

7号 楼	7号 楼3 层				底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
					东外墙	0.8	3.1	2.5	0.44	0.70	-0.05	0.00	0.00	25.9			25.9
				房间小计	室内温度℃	18		室外温度℃	-6.2	房高修正	0			851.7	0.0	0.0	851.7
				3006[客餐 厅]	南外墙	0.7	3.1	2.2	0.44	1.00	-0.20	0.00	0.00	25.9			25.9
					南外墙	6.4	3.1	19.840-13.8	0.44	0.70	-0.20	0.00	0.00	50.8			50.8
					南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	2.9	0.0	529.6
					东内墙	3.7	3.1	11.470-2.8	1.45	0.70	0.00	0.00		299.5			299.5
					东内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
					东外墙	1.1	3.1	3.410-2.0	0.44	1.00	-0.05	0.00	0.00	20.0			20.0
					东外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	1.6	0.0	130.3
				房间小计	室内温度℃	18		室外温度℃	-6.2	房高修正	0			1182.5	4.5	0.0	1187.0
				3007[卧室]	南外墙	3.4	3.1	10.385-4.0	0.44	1.00	-0.20	0.00	0.00	81.0			81.0
					矩形凸窗_嵌									386.3			386.4
					东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	3.5		76.9
					西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	8.5		81.9
					南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	5.1		223.4
					顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
					底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
					北内墙	3.4	3.1	10.4	1.45	0.70	0.00	0.00		357.1			357.1
				房间小计	室内温度℃	18		室外温度℃	-6.2	房高修正	0			824.5	0.0	0.0	824.5
				户型小计										4157.4	51.6	0.0	4209.0
				3008[厨房]	东外墙	1.5	3.1	4.7	0.44	1.00	-0.05	0.00	0.00	55.0			55.0
					北外墙	4.1	3.1	12.710-3.7	0.44	1.00	0.10	0.00	0.00	122.8			122.8
					北外窗_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	12.3		228.4
					西外墙	2.3	3.1	7.1	0.44	1.00	-0.05	0.00	0.00	84.3			84.3
				房间小计	室内温度℃	13		室外温度℃	-6.2	房高修正	0			478.3	12.3	0.0	490.5
				3009[卫]	北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	70.5			70.5
					北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	90.6	10.5		101.2
				房间小计	室内温度℃	18		室外温度℃	-6.2	房高修正	0			161.1	10.5	0.0	171.7
				3010[卧室]	北外墙	3.3	3.1	10.230-2.9	0.44	1.00	0.10	0.00	0.00	120.5			120.5
					北外窗_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	0.00	203.9	13.8		217.8
				房间小计	室内温度℃	18		室外温度℃	-6.2	房高修正	0			324.5	13.8	0.0	338.3
					东外墙	3.6	3.1	11.2	0.44	1.00	-0.05	0.00	0.00	166.4			166.4

D东户	3011[卫]	北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	73.7		73.7	
		北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	10.5	105.3	
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			334.8	10.5	0.0	345.4
	3012[主卧室]	南外墙	3.9	3.1	12.090-4.6	0.44	1.00	-0.20	0.00	0.00	95.4		95.4	
		矩形凸窗_嵌									418.4		418.4	
		东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	3.5	76.9	
		西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	8.5	81.9	
		南外窗_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	5.4	254.9	
		顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4		2.4	
		底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4		2.4	
		东外墙	6.8	3.1	20.9	0.44	1.00	-0.05	0.00	0.00	311.9		311.9	
		西外墙	0.8	3.1	2.5	0.44	0.70	-0.05	0.00	0.00	25.9		25.9	
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			851.7	0.0	0.0	851.7
	3013[客餐厅]	南外墙	0.7	3.1	2.2	0.44	1.00	-0.20	0.00	0.00	27.5		27.5	
		南外墙	6.4	3.1	19.840-13.8	0.44	0.70	-0.20	0.00	0.00	54.0		54.0	
		南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	3.1	0.0	529.7
		西内墙	3.7	3.1	11.470-2.8	1.45	0.70	0.00	0.00		299.5		299.5	
		西内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9		130.9	
		西外墙	1.1	3.1	3.410-2.0	0.44	1.00	-0.05	0.00	0.00	21.0		21.0	
		西外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	9.6	0.0	138.4
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1188.4	12.7	0.0	1201.1
	3014[卧室]	南外墙	3.4	3.1	10.385-4.0	0.44	1.00	-0.20	0.00	0.00	81.0		81.0	
		矩形凸窗_嵌									386.3		386.4	
		东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	3.5	76.9	
		西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	8.5	81.9	
		南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	5.1	223.4	
		顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1		2.1	
		底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1		2.1	
		北内墙	3.4	3.1	10.4	1.45	0.70	0.00	0.00		357.1		357.1	
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			824.5	0.0	0.0	824.5
	户型小计										4163.2	59.9	0.0	4223.1
	楼层小计										8320.6	111.5	0.0	8432.1
		西外墙	1.5	3.1	4.7	0.44	1.00	-0.05	0.00	0.00	55.0		55.0	

D西户

4001[厨房]	北外墙	4.1	3.1	12.710-3.7	0.44	1.00	0.10	0.00	0.00	122.8			122.8
	北外墙_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	0.0		216.1
	东外墙	2.3	3.1	7.1	0.44	1.00	-0.05	0.00	0.00	84.3			84.3
房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0			478.3	0.0	0.0	478.3
4002[卫]	北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	70.5			70.5
	北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	90.6	0.0		90.6
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			161.1	0.0	0.0	161.1
4003[卧室]	北外墙	3.3	3.1	10.230-2.9	0.44	1.00	0.10	0.00	0.00	120.5			120.5
	北外墙_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	0.00	203.9	0.0		203.9
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			324.5	0.0	0.0	324.5
4004[卫]	西外墙	3.6	3.1	11.2	0.44	1.00	-0.05	0.00	0.00	166.4			166.4
	北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	73.7			73.7
	北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	0.0		94.8
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			334.8	0.0	0.0	334.8
4005[主卧室]	西外墙	6.8	3.1	20.9	0.44	1.00	-0.05	0.00	0.00	311.9			311.9
	南外墙	3.9	3.1	12.090-4.6	0.44	1.00	-0.20	0.00	0.00	95.4			95.4
	矩形凸窗_嵌									401.0			401.0
	东外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	西外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	南外墙_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	0.0		249.5
	顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
	底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
	东外墙	0.8	3.1	2.5	0.44	0.70	-0.05	0.00	0.00	25.9			25.9
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			834.2	0.0	0.0	834.2
4006[客餐厅]	南外墙	0.7	3.1	2.2	0.44	1.00	-0.20	0.00	0.00	25.9			25.9
	南外墙	6.4	3.1	19.840-13.8	0.44	0.70	-0.20	0.00	0.00	50.8			50.8
	南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	0.0	0.0	526.6
	东内墙	3.7	3.1	11.470-2.8	1.45	0.70	0.00	0.00		299.5			299.5
	东内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
	东外墙	1.1	3.1	3.410-2.0	0.44	1.00	-0.05	0.00	0.00	20.0			20.0
	东外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	0.0	0.0	128.7
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1182.5	0.0	0.0	1182.5
		南外墙	3.4	3.1	10.385-4.0	0.44	1.00	-0.20	0.00	81.0			81.0

7号 楼4 层	D东户	4007[卧室]	矩形凸窗_嵌								369.2			369.2
			东外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0	73.4
			西外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0	73.4
			南外墙_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	0.0	218.3
			顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1		2.1
			底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1		2.1
			北内墙	3.4	3.1	10.4	1.45	0.70	0.00	0.00		357.1		357.1
			房间小计	室内温度℃	18	室外温度℃	-6.2	房高修正	0			807.4	0.0	807.4
		户型小计										4122.8	0.0	4122.8
		4008[厨房]	东外墙	1.5	3.1	4.7	0.44	1.00	-0.05	0.00	0.00	55.0		55.0
			北外墙	4.1	3.1	12.710-3.7	0.44	1.00	0.10	0.00	0.00	122.8		122.8
			北外墙_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	0.0	216.1
			西外墙	2.3	3.1	7.1	0.44	1.00	-0.05	0.00	0.00	84.3		84.3
		房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0			478.3	0.0	478.3
		4009[卫]	北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	70.5		70.5
			北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	90.6	0.0	90.6
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			161.1	0.0	161.1
		4010[卧室]	北外墙	3.3	3.1	10.230-2.9	0.44	1.00	0.10	0.00	0.00	120.5		120.5
			北外墙_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	0.00	203.9	0.0	203.9
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			324.5	0.0	324.5
		4011[卫]	东外墙	3.6	3.1	11.2	0.44	1.00	-0.05	0.00	0.00	166.4		166.4
			北外墙	1.8	3.1	5.580-1.3	0.44	1.00	0.10	0.00	0.00	73.7		73.7
			北外墙_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	0.0	94.8
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			334.8	0.0	334.8
		4012[主卧 室]	南外墙	3.9	3.1	12.090-4.6	0.44	1.00	-0.20	0.00	0.00	95.4		95.4
			矩形凸窗_嵌									401.0		401.0
			东外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0	73.4
			西外墙_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0	73.4
			南外墙_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	0.0	249.5
			顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4		2.4
			底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4		2.4
			东外墙	6.8	3.1	20.9	0.44	1.00	-0.05	0.00	0.00	311.9		311.9
			西外墙	0.8	3.1	2.5	0.44	0.70	-0.05	0.00	0.00	25.9		25.9

房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			834.2	0.0	0.0	834.2
4013[客餐厅]	南外墙	0.7	3.1	2.2	0.44	1.00	-0.20	0.00	0.00	27.5			27.5
	南外墙	6.4	3.1	19.840-13.8	0.44	0.70	-0.20	0.00	0.00	54.0			54.0
	南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	0.0	0.0	526.6
	西内墙	3.7	3.1	11.470-2.8	1.45	0.70	0.00	0.00		299.5			299.5
	西内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
	西外墙	1.1	3.1	3.410-2.0	0.44	1.00	-0.05	0.00	0.00	21.0			21.0
	西外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	0.0	0.0	128.7
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1188.4	0.0	0.0	1188.4
4014[卧室]	南外墙	3.4	3.1	10.385-4.0	0.44	1.00	-0.20	0.00	0.00	81.0			81.0
	矩形凸窗_嵌									369.2			369.2
	东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	0.0		218.3
	顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
	底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
	北内墙	3.4	3.1	10.4	1.45	0.70	0.00	0.00		357.1			357.1
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			807.4	0.0	0.0	807.4
户型小计										4128.7	0.0	0.0	4128.7
楼层小计										8251.5	0.0	0.0	8251.5
	5001[厨房]	西外墙	1.5	3.0	4.5	0.44	1.00	-0.05	0.00	53.2			53.2
		北外墙	4.1	3.0	12.300-3.7	0.44	1.00	0.10	0.00	117.2			117.2
		北外窗_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	216.1	0.0		216.1
		东外墙	2.3	3.0	6.9	0.44	1.00	-0.05	0.00	81.6			81.6
		屋面	4.0	2.4	9.4	0.24	1.00	0.00	0.00	60.8			60.8
	房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0		529	0.0	0.0	529.0
	5002[卫]	北外墙	1.8	3.0	5.400-1.3	0.44	1.00	0.10	0.00	67.6			67.6
		北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	90.6	0.0		90.6
		屋面	4.0	1.6	6.5	0.24	1.00	0.00	0.00	52.7			52.7
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0		210.9	0.0	0.0	210.9
	5003[卧室]	北外墙	3.3	3.0	9.900-2.9	0.44	1.00	0.10	0.00	115.1			115.1
		北外窗_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	203.9	0.0		203.9
		屋面	4.0	3.0	11.9	0.24	1.00	0.00	0.00	96.6			96.6

D西户

房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			415.6	0.0	0.0	415.6
5004[卫]	西外墙	3.6	3.0	10.8	0.44	1.00	-0.05	0.00	0.00	161.0			161.0
	北外墙	1.8	3.0	5.400-1.3	0.44	1.00	0.10	0.00	0.00	70.6			70.6
	北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	0.0		94.8
	屋面	4.0	1.6	6.5	0.24	1.00	0.00	0.00	0.00	52.7			52.7
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			379.1	0.0	0.0	379.1
5005[主卧室]	西外墙	6.8	3.0	20.3	0.44	1.00	-0.05	0.00	0.00	301.9			301.9
	南外墙	3.9	3.0	11.700-4.6	0.44	1.00	-0.20	0.00	0.00	90.5			90.5
	矩形凸窗_嵌									401.0			401.0
	东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	南外窗_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	0.0		249.5
	顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
	底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4
	东外墙	0.8	3.0	2.4	0.44	0.70	-0.05	0.00	0.00	25.0			25.0
	屋面	4.0	6.1	24.4	0.24	1.00	0.00	0.00	0.00	198.2			198.2
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1016.6	0.0	0.0	1016.6
5006[客餐厅]	南外墙	0.7	3.0	2.1	0.44	1.00	-0.20	0.00	0.00	25.0			25.0
	南外墙	6.4	3.0	19.200-13.8	0.44	0.70	-0.20	0.00	0.00	45.5			45.5
	南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	0.0	0.0	526.6
	东内墙	3.7	3.0	11.100-2.8	1.45	0.70	0.00	0.00		286.8			286.8
	东内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
	东外墙	1.1	3.0	3.300-2.0	0.44	1.00	-0.05	0.00	0.00	18.4			18.4
	东外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	0.0	0.0	128.7
	屋面	4.0	13.9	55.7	0.24	1.00	0.00	0.00	0.00	452.7			452.8
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1614.8	0.0	0.0	1614.8
5007[卧室]	南外墙	3.4	3.0	10.050-4.0	0.44	1.00	-0.20	0.00	0.00	76.8			76.8
	矩形凸窗_嵌									369.2			369.2
	东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	0.0		218.3
	顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
	底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1

7号 楼5 层			北内墙	3.4	3.0	10.1	1.45	0.70	0.00	0.00		345.6			345.6
			屋面	4.0	3.3	13.3	0.24	1.00	0.00	0.00	0.00	108.5			108.5
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			900.1	0.0	0.0	900.1
	户型小计										5066.1	0.0	0.0	5066.1	
	D东户	5008[厨房]	东外墙	1.5	3.0	4.5	0.44	1.00	-0.05	0.00	0.00	53.2			53.2
			北外墙	4.1	3.0	12.300-3.7	0.44	1.00	0.10	0.00	0.00	117.2			117.2
			北外窗_嵌	2.3	1.6	3.7	1.90	1.00	0.10	0.00	0.00	216.1	0.0		216.1
			西外墙	2.3	3.0	6.9	0.44	1.00	-0.05	0.00	0.00	81.6			81.6
			屋面	4.0	2.4	9.4	0.24	1.00	0.00	0.00	0.00	60.8			60.8
		房间小计		室内温度℃	13	室外温度℃	-6.2	房高修正	0			529	0.0	0.0	529.0
		5009[卫]	北外墙	1.8	3.0	5.400-1.3	0.44	1.00	0.10	0.00	0.00	67.6			67.6
			北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	90.6	0.0		90.6
			屋面	4.0	1.6	6.5	0.24	1.00	0.00	0.00	0.00	52.7			52.7
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			210.9	0.0	0.0	210.9
		5010[卧室]	北外墙	3.3	3.0	9.900-2.9	0.44	1.00	0.10	0.00	0.00	115.1			115.1
			北外窗_嵌	1.8	1.6	2.9	1.90	1.00	0.10	0.00	0.00	203.9	0.0		203.9
			屋面	4.0	3.0	11.9	0.24	1.00	0.00	0.00	0.00	96.6			96.6
		房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			415.6	0.0	0.0	415.6
		5011[卫]	东外墙	3.6	3.0	10.8	0.44	1.00	-0.05	0.00	0.00	161.0			161.0
			北外墙	1.8	3.0	5.400-1.3	0.44	1.00	0.10	0.00	0.00	70.6			70.6
			北外窗_嵌	0.8	1.6	1.3	1.90	1.00	0.10	0.00	0.00	94.8	0.0		94.8
	屋面		4.0	1.6	6.5	0.24	1.00	0.00	0.00	0.00	52.7			52.7	
	房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			379.1	0.0	0.0	379.1	
	5012[主卧室]	南外墙	3.9	3.0	11.700-4.6	0.44	1.00	-0.20	0.00	0.00	90.5			90.5	
		矩形凸窗_嵌									401.0			401.0	
		东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4	
		西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4	
		南外窗_子	2.4	1.9	4.6	1.90	1.00	-0.20	0.00	0.00	249.5	0.0		249.5	
		顶楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4	
		底楼板_子	2.4	0.6	1.4	0.39	1.00	0.00	0.00		2.4			2.4	
		东外墙	6.8	3.0	20.3	0.44	1.00	-0.05	0.00	0.00	301.9			301.9	
		西外墙	0.8	3.0	2.4	0.44	0.70	-0.05	0.00	0.00	25.0			25.0	
		屋面	4.0	6.1	24.4	0.24	1.00	0.00	0.00	0.00	198.2			198.2	

房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1016.5	0.0	0.0	1016.5
5013[客餐厅]	南外墙	0.7	3.0	2.1	0.44	1.00	-0.20	0.00	0.00	26.6			26.6
	南外墙	6.4	3.0	19.200-13.8	0.44	0.70	-0.20	0.00	0.00	48.3			48.3
	南外门_嵌	5.5	2.5	13.8	1.90	0.70	-0.20	0.00	0.00	526.6	0.0	0.0	526.6
	西内墙	3.7	3.0	11.100-2.8	1.45	0.70	0.00	0.00		286.8			286.8
	西内门_嵌	1.2	2.3	2.8	2.00	0.70	0.00	0.00		130.9			130.9
	西外墙	1.1	3.0	3.300-2.0	0.44	1.00	-0.05	0.00	0.00	19.4			19.4
	西外门_嵌	0.8	2.5	2.0	1.90	1.00	-0.05	0.00	0.00	128.7	0.0	0.0	128.7
	屋面	4.0	13.9	55.7	0.24	1.00	0.00	0.00	0.00	452.7			452.8
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			1620.2	0.0	0.0	1620.2
5014[卧室]	南外墙	3.4	3.0	10.050-4.0	0.44	1.00	-0.20	0.00	0.00	76.8			76.8
	矩形凸窗_嵌									369.2			369.2
	东外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	西外窗_子	0.6	1.9	1.1	1.90	1.00	-0.05	0.00	0.00	73.4	0.0		73.4
	南外窗_子	2.1	1.9	4.0	1.90	1.00	-0.20	0.00	0.00	218.3	0.0		218.3
	顶楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
	底楼板_子	2.1	0.6	1.3	0.39	1.00	0.00	0.00		2.1			2.1
	北内墙	3.4	3.0	10.1	1.45	0.70	0.00	0.00		345.6			345.6
	屋面	4.0	3.3	13.3	0.24	1.00	0.00	0.00	0.00	108.5			108.5
房间小计		室内温度℃	18	室外温度℃	-6.2	房高修正	0			900.1	0.0	0.0	900.1
户型小计										5071.4	0.0	0.0	5071.4
楼层小计										10137.6	0.0	0.0	10137.6
建筑小计										44008.7	719.6	0.0	44728.2
向下传热量													5310.2
工程合计										44008.7	719.6	0.0	50038.4