

楼层/房间	房间面积	设计照度	平均照度	最小照度	最大照度	照度均匀度
○-1						
└ -1097[楼梯间]	4.62	150	251	155	325	0.61
○1						
└ 1021[走道]	23.4	150	85	2	393	0.02
└ 1066[走道]	8.19	150	0	0	0	0
└ 1009[大堂]	47.57	300	816	195	1204	0.24
└ 1095[楼梯间]	4.62	150	489	392	532	0.8
└ 1024[办公室]	21.24	450	1040	656	1646	0.63
└ 1002[餐厅]	122.71	150	1154	506	2447	0.44
└ 1124[卫生间]	2.94	150	0	0	0	0
└ 1102[卫生间]	4.25	150	782	588	961	0.75
└ 1126[卫生间]	2.71	150	0	0	0	0
└ 1059[楼梯间]	13.72	150	558	288	939	0.52
└ 1049[楼梯间]	15.02	150	522	203	831	0.39
└ 1060[办公室]	10.44	450	623	452	758	0.73
└ 1064[卫生间]	8.5	150	812	485	1091	0.6
└ 1061[办公室]	10.12	450	1417	683	2704	0.48
└ 1062[卫生间]	8.32	150	1315	378	2208	0.29
○2						
└ 2096[楼梯间]	4.62	150	514	400	569	0.78
└ 2053[楼梯间]	14.89	150	712	390	1213	0.55
└ 2018[会议室]	28.1	450	513	178	1910	0.35
└ 2004[走道]	65.91	150	343	4	2202	0.01
└ 2065[卫生间]	8.2	150	824	191	1593	0.23
└ 2067[卫生间]	5.21	150	851	645	1069	0.76
└ 2046[楼梯间]	15.44	150	803	434	1073	0.54
└ 2017[办公室]	28.96	450	916	420	1098	0.46
└ 2011[办公室]	36.95	450	926	382	1128	0.41
└ 2063[卫生间]	8.5	150	254	80	491	0.31
└ 2016[办公室]	28.75	450	418	66	1859	0.16
└ 2012[办公室]	28.78	450	521	170	1822	0.33
└ 2015[办公室]	28.78	450	526	175	2046	0.33
└ 2013[办公室]	28.78	450	520	165	1966	0.32
└ 2014[办公室]	28.78	450	530	182	2019	0.34
└ 2019[办公室]	28.02	450	526	165	1900	0.31
○3						
└ 3001[楼梯间]	15.44	150	678	304	1068	0.45
└ 3003[走道]	65.08	150	700	64	1981	0.09
└ 3116[卫生间]	3.67	150	623	512	684	0.82
└ 3115[卫生间]	3.67	150	622	514	687	0.83
└ 3114[卫生间]	3.67	150	623	511	688	0.82
└ 3105[卫生间]	3.98	150	618	489	686	0.79
└ 3104[卫生间]	3.98	150	619	492	687	0.79
└ 3103[卫生间]	3.98	150	619	498	688	0.81
└ 3068[楼梯间]	5	150	486	389	541	0.8
└ 3052[楼梯间]	14.89	150	715	387	1195	0.54
└ 3056[办公室]	14.8	450	1176	725	1891	0.62
└ 3025[办公室]	19.34	450	985	210	1874	0.21
└ 3099[卫生间]	4.43	150	595	453	666	0.76
└ 3123[卫生间]	3.57	150	622	518	684	0.83

└ 3043[办公室]	19.08	450	1057	227	1906	0.21
└ 3034[办公室]	19.42	450	988	221	1913	0.22
└ 3045[办公室]	19.08	450	1057	239	1920	0.23
└ 3032[办公室]	19.42	450	986	216	1825	0.22
└ 3044[办公室]	19.08	450	1058	229	1940	0.22
└ 3033[办公室]	19.4	450	982	217	1733	0.22
○4						
└ 4039[办公室]	19.08	450	1519	352	2312	0.23
└ 4005[走道]	65.02	150	851	83	1792	0.1
└ 4042[办公室]	19.08	450	1403	287	2277	0.2
└ 4026[办公室]	19.42	450	1443	368	2289	0.25
└ 4047[楼梯间]	15.43	150	1068	502	1402	0.47
└ 4051[楼梯间]	14.89	150	1114	611	1510	0.55
└ 4121[卫生间]	3.67	150	1014	735	1187	0.72
└ 4030[办公室]	19.4	450	1346	312	2106	0.23
└ 4117[卫生间]	3.67	150	1024	747	1183	0.73
└ 4027[办公室]	19.42	450	1444	385	2223	0.27
└ 4106[卫生间]	3.98	150	1009	717	1188	0.71
└ 4108[卫生间]	3.98	150	1017	746	1184	0.73
└ 4037[办公室]	19.08	450	1524	386	2329	0.25
└ 4119[卫生间]	3.67	150	1081	841	1249	0.78
└ 4107[卫生间]	3.98	150	1025	802	1191	0.78
└ 4055[办公室]	14.99	450	1607	1068	2260	0.66
└ 4101[卫生间]	4.53	150	987	754	1163	0.76
└ 4113[卫生间]	3.77	150	1024	762	1188	0.74
└ 4036[办公室]	19.31	450	1448	381	2273	0.26
└ 4070[楼梯间]	5	150	855	624	987	0.73
○5						
└ 5040[办公室]	19.08	450	608	139	1512	0.23
└ 5006[走道]	65.02	150	580	19	1828	0.03
└ 5041[办公室]	19.08	450	606	159	1487	0.26
└ 5028[办公室]	19.42	450	551	151	1325	0.27
└ 5048[楼梯间]	15.43	150	348	218	750	0.63
└ 5050[楼梯间]	14.89	150	380	226	835	0.6
└ 5122[卫生间]	3.67	150	0	0	0	0
└ 5031[办公室]	19.4	450	514	112	1265	0.22
└ 5118[卫生间]	3.67	150	0	0	0	0
└ 5029[办公室]	19.42	450	550	148	1402	0.27
└ 5109[卫生间]	3.98	150	0	0	0	0
└ 5111[卫生间]	3.98	150	0	0	0	0
└ 5038[办公室]	19.08	450	606	154	1486	0.25
└ 5120[卫生间]	3.67	150	0	0	0	0
└ 5110[卫生间]	3.98	150	0	0	0	0
└ 5054[办公室]	14.99	450	648	277	1432	0.43
└ 5100[卫生间]	4.53	150	0	0	0	0
└ 5112[卫生间]	3.77	150	0	0	0	0
└ 5035[办公室]	19.31	450	561	154	1412	0.28
└ 5069[楼梯间]	5	150	195	144	236	0.74
○6						
└ 6022[楼梯间]	23.26	150	669	289	1067	0.43
└ 6057[楼梯间]	14.18	150	667	408	961	0.61